

ABOVEGROUND STORAGE TANK INSPECTION RECORD (AQUA AMMONIA)

Inspector Name: _____

Inspection Date: _____

Aboveground Storage Tanks ¹	YES	NO	NA	OBSERVATIONS / COMMENTS
Is the tank free of leaks?				
Debris or fire hazard in containment?				
Is the tank free of visible cracks, blistering, bulging, corrosion, or other damage?				
Are all tank appurtenances (piping, valves, fittings, etc.) free of visible signs of wetting or leakage?				
Are all tank openings are properly sealed?				
Conservation vent is free of obstructions?				
Tank Marked by Product?				
Tank Marked with NFPA Diamond?				
Are the tank valves equipped with locking mechanisms to protect from unauthorized use?				
Is the Liquid Level/Site Gauge in Good Condition?				
Does the dead man valve at bottom of sight tube open and close and free of leaks?				
Are there other conditions that should be addressed for continued safe operation?				

NOTES:

- Internal and External Inspections and Testing of Steel ASTs will be conducted in accordance with the STI Standards.